

C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2024/ 88

Dated: 29/02/2024

To,

Mr. Anurag Singhal, Addl. General Manager (Engg.)
Corporate Office,
NBCC Bhawan, Lodi Road,
New Delhi-110003.

Sub: Issue of FSC in r/o LNJN National Institute of Criminology & Forensic Science, (NFSU Delhi Campus), Sector-III, Rohini, Delhi-110085.

Sir,

In Continuation with to this Department letter no.1798 dated 08.09.2021 sub-sequent your online e-mail dated 13.01.2024 received in this department, In this connection it is to inform you that the building premises has been visited by the officers concerned of this department on **16.02.2024** presence of **Sh. Nirang Dave, Registrar** and observed that the shortcoming already issued by this department letter of even No. 1798 dated 08.09.2021 are not yet rectified and during the inspection, some shortcomings has been found. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace fire pumps were not found in auto mode.
2. DG pump was found not operational due to missing battery.
3. Pressurization fan of lift shaft found removed.

In this regard as stipulated in sub Rule 35 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "I" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rule
[s/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours Faithfully

(Atul Garg)

DIRECTOR

Ph; 011-23414000

re
sig