

c-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/NDZ/2024/ 82

Dated: 27/02/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s **Pizza Hut** (A unit of M/s Devyani International Ltd.) located at **Qutab Road, Sadar Bazar, Delhi - 06.**

Sir,

This has reference to online application ID No. 2024012000644 dated 08.02.2024 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 21.02.2024 in presence of Mr. Sahel (RGM) and it was observed that building is comprised of 02 Basement + Ground + 04 upper floors (but restaurant at ground floor only). During inspection, following shortcomings were observed:

1. 02 nos. of doors are provided having width of 1.20 m & 0.80 m respectively against the requirement of 1.5 m each.
2. First aid hose reel not provided.
3. Overhead water storage tank provided 10,000 liters against the requirement of 20,000 liters.
4. Plan of the restaurant duly signed by architect and owner/ occupier.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director d/c
Delhi Fire Service
Tel: 01123414000
26/2

Copy to:-

The Manager,
M/s Pizza Hut (A unit of Devyani International Ltd.), Qutab Road, Sadar Bazar, Delhi - 06.