## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/WZ/2024/84

Dated: 27/02 /2024

Yours faithfully

Atul Garg) Director

OLL

clir

To,

The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s

Pizza Hut (A Unit of Ms Divyani international Ltd) Located at Shop No. A 25

Ground Floor, Tagore Market, Kirti Nagar, New Delhi-110015.

Sir,

Please refer to your online application no. 2024020801390 dated - 08/02/2024 on the subject cited above. In this connection, it is to inform you that the premises was re inspected by officer concerned of this department on 19/02/2024 in the presence of Sh. Satish Kumar (Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at Ground Floor in a Building comprised of Ground + 02 Upper floors. Fire safety arrangements such as Fire Extinguishers provided. However the following shortcomings were observed.

- 1. Width of door size is provided 1.00m x 1 against requirement of 1.5m x 2.
- 2. Smoke management system is not provided.
- 3. First-Aid Hose Reels is not provided.
- 4. MOEFA is not provided.
- 5. Internal Hydrant is not provided.
- 6. Main Fire Pump of capacity 450 lpm is not provided.
- 7. Access of tank & Over head water storage capacity of 20,000ltr is not provided.
- 8. Exit Signages is not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Copy to: -

The Owner/Occupier, M/s Pizza Hut (A Unit of Ms Divyani international Ltd) Located at Shop No. A Ground Floor, Tagore Market, Kirti Nagar, New Delhi-110015. (Online application no. 2024020801390 dated: 08/02/2024)

 The DHO, West Zone, MCD, Shivaji Enclave, Raja Garden, New Delhi- 110027. (dhowest zone@gmail.com)