



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/ 83

Dated: 28/02/2024

To

Sh. Naresh Kumar Yadav
(ASO/ Fire Officer),
Administrative Block, AIIMS,
Ansari Nagar, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Private and V.I.P. Paid Ward, AIIMS Complex, Ansari Nagar, New Delhi-110029**

Sir,

This has reference to the email dated 11/10/2023, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 21/02/2024 in the presence of Mr. Rajneesh (AE/E) and Mr. Vimal Kumar (JE/E). During the course of inspection, the shortcomings observed are as below.

1. The width of internal road found reduced/obstructed at some places due to non-trimming of branches/trees.
2. Automatic fire detection & alarming system found provided but non-functional.
3. MOEFA/MCPs found provided but non-functional.
4. PA system found non-functional/under repair.
5. Some of the fire hose-boxes near internal & yard hydrants found empty/without branch & hoses.
6. Lift signage found removed.
7. 8th and 9th floor found locked. Hence, fire safety arrangements could not be checked.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029