

G/SS

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/School/2024/ 92

Dated: 01/03/2024

To,

The Principal,
A-One International Public School,
B-Block, Inder Enclave Phase-I,
Delhi-110086,

Sub: Issue of FSC in r/o A-One International Public School, B-Block, Inder Enclave Phase-I, Delhi-110086.

Sir,

Kindly reference to online e-mail dated 10.01.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 23.02.2024, in presence of **Mr. Dalbir (Chairman)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 08 fire extinguishers of ABC type provided against the required 16 no's of ABC / Co2 type 2.5 kg capacity required to be provided.
2. Automatic sprinkler system in basement provided but not functional.
3. Auto starting/Manual stopping system of pumps not functional.
4. Terrace Fire pump with capacity of 900 LPM provided but not functional.
5. 15,000 ltrs Over Head water captive tank provided but found empty.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule
[s/http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)

Yours faithfully


(Adul Garg)
DIRECTOR
Ph; 011-23414000
OK
By