



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/SZ/2024/ 89

Dated: 01 /03 /2024

To

Sh. A.K. Shrivastava (Advisor-E), Central Board of Irrigation & Power, Plot No. 4, Institutional Area, Malcha Marg, Chanakyapuri, New Delhi-110021

Sub: Renewal of Fire Safety Certificate in r/o Central Board of Irrigation & Power building at Plot No. 4, Institutional Area, Malcha Marg, Chanakyapuri, New Delhi-110021

Sir,

This has reference to your letter no. 887/Buil.Main/Fire dated 19/12/2023, received through outdoor diary no. 12482 dated 31/01/2024 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 23/02/2024 in the presence of Mr. R.K. Aggarwal (Water Resource Consultant). During the course of inspection, the shortcomings observed are as below.

- 1. Staircase at 2nd floor found blocked with office material.
- 2. Basement floor found used for Offices, erecting cabins.
- 3. First aid hose reel found provided but non-functional.
- 4. Automatic smoke detection system found non-functional and removed at some places.
- Sprinklers in basement found non-functional and to be extended in left-out area also some sprinklers covered under false ceiling.
- Terrace level fire pumps found provided but not on auto mode.
- 7. Access to overhead water storage tanks not provided for inspection.
- 8. Fireman grounding switch found removed and lift signage removed at 3rd floor.
- 9. Repair/renovation work being carried out at 2nd floor.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

DIRECTOR

DELLE FIRE SERVICE

Copy to: -

 The Director, Central Board of Irrigation & Power, Plot No. 4, Institutional Area, Malcha Marg, Chanakyapuri, New Delhi-110021