



75
Azadi Ka
Amrit Mahotsav

c/29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 96

Dated: 01/03/2024

To

The Principal,
Govt. Co. Ed. Sr. Sec. School,
Laxmi Bai Nagar, New Delhi-110023

Sub: Regarding renewal of Fire Safety Certificate in r/o Govt. Co. Ed. Sr. Sec. School, Laxmi Bai Nagar, New Delhi-110023 (School ID: 1719101)

Sir,

This has reference to your letter received through outdoor diary no. 109744 dated 18/12/2023, on the subject cited above. In this connection, the school premises was visited by the officer concerned of this department on 23/02/2024 in the presence of Sh. Ranvir Singh (Principal) to verify the status of the fire safety arrangements provided therein. During the inspection, the shortcomings observed are as below.

1. The hose-reel hose found provided but non-functional.
2. The terrace level fire pumps found provided but non-functional.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/03

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054