



0/82
75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 89

Dated: 01/03/2024

To

The Principal,
Govt. Girls Sr. Sec. School,
Block ABC (SPS) Building,
Smalka, New Delhi-110097

Sub: Regarding renewal of Fire Safety Certificate in r/o Govt. Girls Sr. Sec. School, Block ABC (SPS) Building, Smalka, New Delhi- (School ID:1821280)

Sir,

This has reference to your letter No. GGSSS/SAM/2023/665 dated 26/12/2023, on the subject cited above. In this connection, the school premises was visited by the officer concerned of this department on 16/02/2024 to verify the status of the fire safety arrangements provided therein. During the inspection Mr. Mahesh Chandra (Estate Officer) was present; the shortcomings observed are as below.

1. The hose-reel hose found provided but non-functional & nozzle missing.
2. The terrace pump found provided but non-functional.
3. Overhead water tank could not be checked as access to tank is not provided.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054