

c/81

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/94 | 81

Dated: 01/03/2024

To

The Joint Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in respect of M/s Hotel Paras International, Located at WEA, Karol Bagh, New Delhi-110005.**

Sir,

Please refer to online application No. 2024020901446, dated 14/02/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 27/02/2024 in the presence of Sh. Surender (Manager) from fire safety point of view.

During the course of inspection following shortcomings were observed:

1. Fire Check Doors found not provided.
2. Smoke management system found nonfunctional/ inadequate at upper floors.
3. CO Detectors not provided in entire guest house.
4. MOEFA and PA system found nonfunctional.
5. Pumps at terrace level found nonfunctional in auto mode.
6. The basement found closed. *under ownership of other.*

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

  
(Anil Garg)  
Director  
Delhi Fire Service  
dc  
28/2/24

Copy to: - The Manager, M/s Hotel Paras International, Located at WEA, Karol Bagh, New Delhi-110005.