



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 94

Dated: 01/03/2024

To

The Principal,
Sarvodaya Bal Vidyalaya,
Delhi Cantt, New Delhi-110010

Sub: Regarding renewal of Fire Safety Certificate in r/o Sarvodaya Bal Vidyalaya, Delhi Cantt, Tigris Road, New Delhi-110010 (School ID: 1720001)

Sir,

This has reference to your letter No. SBV/DC/23-24/812 dated 23/11/2023, on the subject cited above. In this connection, the school premises was visited by the officer concerned of this department on 14/02/2024 to verify the status of the fire safety arrangements provided therein. During the inspection Mr. Ratti Ram (Estate Officer) was present; the shortcomings observed are as below.

1. The portable fire extinguishers found empty/unrefilled.
2. The hose-reel hose found provided but non-functional.
3. The fire terrace pump was not on auto mode.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/03/24

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054