



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 88

Dated: 01/03/2024

To

The Principal,
Sarvodaya Vidyalaya (Rani Durgawati),
East Kidwai Nagar,
New Delhi-110023

Sub: Regarding renewal of Fire Safety Certificate in r/o Sarvodaya Vidyalaya (Rani Durgawati), East Kidwai Nagar, New Delhi-110023 (School ID:1924039)

Sir,

This has reference to your email dated 16/02/2024, on the subject cited above. In this connection, the school premises was visited by the officer concerned of this department on 21/02/2024 to verify the status of the fire safety arrangements provided therein. During the inspection Sh. Satvir Singh (Estate Officer) was present; the shortcomings observed are as below.

1. The hose-reel hose found provided but non-functional & nozzle missing.
2. MOEFA/MCPs found provided but non-functional.
3. PA system found provided but non-functional.
4. The terrace pump found provided but non-functional.
5. Exit signage's found removed at some places.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/03

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054