

C-23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2024/School/ 91

Dated: 01/03/2024

To,

The Principal,
Tulip Public School,
Sector-24, Pocket-20, Rohini,
Delhi-85

Sub: Issue of FSC in r/o Tulip Public School, Sector-24, Pocket-20, Rohini, Delhi-85.

Sir,

Kindly reference to online e-mail dated 31.01.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **21.02.2024**, in presence of **Mr. Gautam Grover** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 4000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000
