

c/36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 79

Dated:- 01.03/2024

To,

The Manger
VANSON DELITE
3672-3674 Street, Dariba Pan,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S The VANSON DELITE, 3672-3674 Street, Dariba Pan, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024021401645 dated 14.02.2024 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 23/02/2024 in the presence of Manager and following shortcomings were observed:

1. Fire Check doors are not installed as per gazette notification 27.05.2019.
2. CO detectors are not installed as per gazette notification 27.05.2019.

Therefore, the case is rejected with a request to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Ajul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.