



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024 | 87

Dated: 01/03/2024

To

The Principal,
Wisdom Creative School (Run by Tali Pop Foundation),
Plot No. 181, 182, 183 & 184, Jaitpur Extn. Part-2,
Badarpur, New Delhi- 44.

Sub:- Regarding issuance of Fire Safety Certificate in r/o M/s Wisdom Creative School (Run by Tali Pop Foundation) located at Plot No. 181, 182, 183 & 184, Jaitpur Extn. Part-2, Badarpur, New Delhi- 44.

Sir,

With reference to letter bearing outdoor diary no. 12246 dated 25.01.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 21.02.2024 in the presence of Mr. Javed Ali (Owner) and it was observed that the building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. 2 nos. of staircases 1.50 meters each not provided in the building.
2. First aid hose reels found non functional.
3. Fire pump found non functional.
4. Terrace water tank of 10,000 liters not provided (exclusively for firefighting).
5. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

22/2/24

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.