



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/ 101

Dated: 05/03/2024

To

The Executive Engineer (E),
SJHED Central Public Works Department,
Safdarjung Hospital Complex,
Ring Road, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Vardhaman Mahavir Medical College,
Safdarjung Hospital Complex, Ring Road, New Delhi-110029**

Sir,

This has reference to the email dated 19/01/2024, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 26/02/2024 in the presence of Mr. Vivek Gupta (JE/Elect). During the course of inspection, the shortcomings observed are as below.

1. The smoke management system is not integrated.
2. The first aid hose-reel found non-functional and without shut off nozzle.
3. Automatic fire detection & alarming system found provided but non-functional at some places and not provided in some offices as indicated during inspection.
4. MOEFA/MCPs found provided but non-functional.
5. PA system found provided but non-functional.
6. Some of the yard hydrants found non-functional and hose-boxes without branch & hoses.
7. The fire pumps provided were not on auto mode.
8. Lift signage found removed.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Medical Superintendent, Safdarjung Hospital, Ring Road, New Delhi-110029