

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F6/DFS/MS/Educational/2024/SZ/95

Dated: 05/03/2024

To,

Mr. Rahul Chaudhary, (Director Administration)
New Delhi Institute for Information Technology & Management,
Plot No.-105, MOR-Pocket, Kalkaji,
New Delhi-110019

Sub: Renewal of Fire Safety Certificate in r/o New Delhi Institute for Information Technology & Management, Plot No.-105, MOR Pocket, Kalkaji, New Delhi-110019.

Sir,

This is in reference to your letter received through outdoor diary no. 13322 dated 20/02/2024 on the subject cited above. In this concerned it is to inform you that the premise was inspected by the concern nominated authority of this department in presence of Mr. Rahul Chawdhary on 27/02/2024 to verify the compliance of fire prevention and fire safety measures required under the rules. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire Check Doors (FCD) of the basement found removed.
2. The auto starting of terrace pumps of both the blocks also not functional.
3. As the plans of the new block were not forwarded by the local authority as specified in section 2(q) of DFS Act-2007 to this department, you are requested to provide a set of completion plans (section, elevation & floor plans) of the new block for the record of this department.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:

1. The Executive Engg.(Bldg.),SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024