



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/102

Dated: 05/03/2024

To

Sh. Naresh Kumar Yadav
(ASO/ Fire Officer),
Administrative Block, AIIMS,
Ansari Nagar, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Surgical Block, Masjid Moth, AIIMS Complex, New Delhi-110029**

Sir,

This has reference to the email dated 10/02/2024, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 26/02/2024 in the presence of Sh. Uma Shanker (JE/E). During the course of inspection, the shortcomings observed are as below.

1. The electrical shaft found unsealed.
2. Temporary construction found at terrace shall be got regularized from concerned authority or same should be removed.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Director, All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029
2. The Chief Architect, NDMC, Department of Architecture & Environs, Palika Kendra, New Delhi-110001