



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/SZ/2024/ 100

Dated: 05 / 03 /2024

To

The Executive Engineer (E),
SJHED Central Public Works Department,
Safdarjung Hospital Complex,
Ring Road, New Delhi-110029

Sub: Renewal of Fire Safety Certificate in r/o Surgical Block, Safdarjung Hospital Complex, Ring Road, New Delhi-110029

Sir,

This has reference to the email dated 19/01/2024, on the subject cited above. In this connection, it is to inform you that the officer concerned of this department inspected the said premises on 26/02/2024 in the presence of Mr. Vivek Gupta (JE/Elect). During the course of inspection, the shortcomings observed are as below.

1. The stairs/escape route found encroached/blocked with office material/furniture.
2. The first aid hose-reel found non-functional and some without shut off nozzle.
3. Hydrant at terrace found blocked with heavy material/almirah
4. Some yard hydrants found in bad condition and hose-boxes at some places without branch & hoses.
5. The fire pumps found removed/under repair (Common Pump Room).
6. Fireman's switch found defective/non-functional.
7. Lift signage found removed.
8. One of the exits at ground floor found closed & locked with chain without securing keys.
9. Waste material & old furniture found stored at terrace, which is hazardous from fire safety point of view.
10. Loose wiring found at top floor.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Medical Superintendent, Safdarjung Hospital, Ring Road, New Delhi-110029