



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F-6/DFS/MS/2024/School/ 103

Dated: 08/03/2024

To,

The Principal
Apex Public School,
At B-Block, Sant Nagar,
Burari, Delhi-110084

Sub: - Regarding grant of fire safety certificate in r/o Apex Public School (New Building) located at B-Block, Sant Nagar, Burari, Delhi-110084.

Sir,

Please refer to your received through online e-mail dated 14.02.2024 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 26.02.2024 in the presence of Dr. Derek Richard Brendish (Principal) to verify the status of the shortcomings already issued by this department vide letter No.F6/DFS/MS/2024/School/33 dated 30.01.2024 and status is as under: -

S No.	Shortcomings	Status
1.	There is two staircase provided width of 02m & 1.50m the second staircase of 02m provided for assembly hall is ground to first floor only and needs to be continues from ground to terrace level.	Not Complied
2.	The door size for assembly hall 1.50m provided against the requirement of 02m.	Not Complied
3.	Hose reel hose provided but not functional.	Provided
4.	MOEFA system not provided.	Not Complied
5.	Internal hydrant provided but not functional.	Provided
6.	Terrace level fire pumps capacity 450lpm provided but not functional.	Provided
7.	Terrace level fire water tank capacity 5,000ltr provided against the requirement of 10, 000ltr.	Not Complied
8.	Exit signage's not provided at strategic location in the school building	Provided
9.	Standby power supply not provided	Not Complied

Keeping in view of above observations, the said building is not safe from fire safety point of view. Hence, you are hereby advised to comply the observations at the earliest under intimation to this department. Any loss of life and property untoward mishap due to non- compliance of the fire safety measures in the event of fire and other emergency the management is solely responsible.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.