GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/EH/2024/ 90

Dated: 04/03 /2024

To,

The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

Subject: Regarding renwal of NOC from fire safety point of view in respect of M/s. Broz (A Unit of NDVN Hospitality Ltd Pvt.) Located UGF-06, Plot No. 7, 8, City Square Mall, Shivaji place, Raja Garden, New Delhi-110027.

Sir,

Please refer to your online application no. 2024020401214 dated 08/02/2024 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 09/01/2024 in the presence of Sh. Narender to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said restaurant is running at upper ground floor in a City Square Mall 02 Basement + Ground + 04 upper floors was issued FSC vide letter no. F6/DFS/MS/WZ/Mall/2023/473 dated 05/10/2023. Fire safety arrangements such as Fire Extinguishers, Smoke Management system, First Aid Hose Reels, Automatic fire detection and alarming system, Internal Hydrants, Pumping Arrangements etc provided. However the following shortcomings were observed.

- 1. MOEFA is found removed.
- 2. Exit signages are found removed.

In view of above Shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

(Atul Garg

Directo

Yours faithfully,

Copy to: -

1. The Owner/Occupier, /s. Broz (A Unit of NDVN Hospitality Ltd Pvt.) Located UGF-06, Plot No. 7, 8, City Square Mall, Shivaji place, Raja Garden, New Delhi-110027. (online application no. 2024020401214 dated 08/02/2024)

 The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi- 110027. (dhowest zone@gmail.com).