

105

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/SZ/2024/ 91

Dated:- 04/03/2024

To,

The Joint C.P. (Lic.),  
1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s. Castle Barbique (A unit of BBQ Castles), located at Shop No. 626, B-1, UGF, Janakpuri, New Delhi- 110058.

Sir,

Please refer to online application ID 2024020201146 dated 05.02.2024 on the subject cited above. Above said eating house running at upper ground floor of a building comprised of stilt, upper ground plus three upper floors. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on 26.02.2024 in presence of Mr. Mahesh (Manager).

During the course of inspection the following shortcomings have been observed:-

- 1 One staircase found blocked with kitchen items.
- 2 Terrace pump capacity 450 LPM found provided but not functional in auto mode.
- 3 Exit Signage found not provided.

Keeping in view of above, fire safety certificate cannot be considered at this stage. Restaurant management may be requested to rectify the above said shortcomings for taking further necessary action in this matter.

Yours faithfully

(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Owner/Occupier, M/s. Castle Barbique (A unit of BBQ Castles), Shop No. 626, B-1, UGF, Janakpuri, New Delhi- 110058