

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No.F6/DFS/MS/SZ/Hospital/2024/ 106

Dated: 08.03.2024

To,

Miss Khushali Oza, AM Legal,
Health Care at Home India Private Limited,
15, West Patel Nagar, New Delhi-110008.

Sub: - Issuances of "Fire Safety Certificate" from fire safety point of view in r/o M/s Health Care at Home India Private Limited situated at 15, West Patel Nagar, New Delhi-110008.

Sir/Madam,

Please refer to your office letter No. Nil, dated 26.02.2024 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the said premises on 06.03.2024 in presence of Sh. Abhay Choudhary and observed that the building comprised of basement, stilt, ground plus three upper floors. Following shortcomings were observed:-

1. Lift lobbies with fire check doors has not provided at each floor.
2. Service shafts and openings have not been sealed at all compartment levels.
3. Smoke management system in basement and upper floor levels not provided.
4. Covers from sprinkler heads and detector heads have not been removed.
5. Underground water storage tank found empty.
6. Floor marking has not done at all levels.
7. Fire fighting pumps are not maintained on auto mode

In view of above, the fire safety certificate cannot be issued at this stage. You are requested to comply the above said shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Anil Garg)
Director

Delhi Fire Service

01c 4

Copy to:

The MS Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, S-1, 3rd
Floor, School Block, Shakarpur, Delhi-110092.