

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/ 84
To

Dated: 04/03/2024

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Hotel Corporate Point Guest House, (A Unit of Tribhuvan Hotels Pvt. Ltd.) located at A-2/7Africa Avenue Marg, Safdarjung Enclave, New Delhi-110029.

Sir,

This has reference with **MHA Portal ID 2024021601750 dated 16/02/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28.02.2024 in the presence of Mr. Avinash (Manager) and observed that the guest house running at 1st 2nd & 3rd upper floors with 19 G/Rooms to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Smoke ventilation system not provided in the building as per clause 7,31 of UBBL 2016.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE