

2/133

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2024/GM/83

DATED: 04/03/2024

To,

The Joint Commissioner of Polite (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate in r/o M/s Hotel Delhi Darbar Located at 15A/26, WEA, Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2023122319869, dated 12/02/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 29/02/2024 in the presence of Sh. Vipin Singh (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Smoke exhaust system at second and third floors is inadequate/ not provided.
2. MOEFA found nonfunctional.
3. Terrace pump found nonfunctional ~~in~~ auto mode.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service.

Copy to:-

1. The Manager, M/s Hotel Delhi Darbar Located at 15A/26, WEA, Karol Bagh, New Delhi - 110005.