

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2024/SZ/ 100
To

Dated: 08/03/2024

The HOS / Vice Principal,
Kendriya Vidyalaya,
Pocket B-5 & 6, Vasant Kunj,
New Delhi 110070.

Sub: Reg. renewal of Fire Safety Certificate in r/o Kendriya Vidyalaya at Pocket B-5 & 6,
Vasant Kunj, New Delhi 110070.

Sir,

This is in reference with your letter F.No 2-6/KV/VK/2023-24/6686 Dated 12/02/2024 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 29.02.2024 in presence of Mr. Rajender Kumar (Principal) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. Fire Extinguishers not refilled.
2. First aid Hose reel provided but found non-functional.
3. Terrace level fire fighting pump provided but found non-functional.
4. Overhead tank capacity 10,000 ltrs found empty.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE