

c/sy

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

**DATED: 07/03/2024**

**NO. F6/DFS/MS/SZ/2024/104**

To,  
The Additional Director,  
National board of Examinations in medical sciences,  
Sector 9 Dwarka New Delhi

**Subject: - Renewal of Fire safety Certificate in r/o National board of Examinations in medical sciences located at Sector 9 Dwarka New Delhi.**

Sir,  
Please refer to your letter No. D-11017/RRFS&I/1/2023/45662 dated 16/02/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 04/03/2024 in the presence of Sh. Sudhir Kumar from fire safety point of view.

During the course of inspection following shortcomings were observed:

1. Six meter wide internal road around the building found encroached.
2. The staircases/ passage/ exits also found obstructed at many places.
3. Smoke exhaust system found nonfunctional in basement.
4. Automatic fire detection system found nonfunctional.
5. Hose reel hose and hydrants found nonfunctional.
6. MOEFA found nonfunctional.
7. Sprinkler system found nonfunctional in basement.
8. All the pumps provided at ground & terrace level found nonfunctional and main valves found closed.
9. Communication system in lift car found nonfunctional.
10. Pressurization system in lift shaft and lift lobby found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter

(Atul Garg)  
Director,  
Delhi Fire Service.

Copy to:-

1. The Joint Director, DDA, INA Vikas Sadan, New Delhi-110023.