



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/ 98

Dated: 08/03/2024

To

The Principal,  
Sarvodaya Kanya Vidyalaya,  
Andrews Ganj, New Delhi-110049

**Sub: Regarding renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya, Andrews Ganj, New Delhi-110049 (School ID: 1924033)**

Sir,

This has reference to the email dated 15/01/2024, on the subject cited above. In this connection, the school premises (Old Block) was visited by the officer concerned of this department on 26/02/2024 to verify the status of the fire safety arrangements provided therein. During the inspection Ms. Sonia Sikka (Vice Principal) was present; the shortcomings observed are as below.

1. The hose-reel hose found provided but non-functional.
2. The terrace level fire pump found provided but non-functional.
3. The piping network found badly rusted/corroded.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

AL 88

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054