



No. F6/DFS/MS/NDZ/EH/2024/ 92

Dated: 04/02/2024

To,

1. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-110024.	2. The Executive Engineer Building Dept., MCD office Shahdara South Zone , karkardoom Court, Delhi
--	--

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Shahi Darbar located at
Property No. old no. 700, Vijay Park Village Maujpur, Delhi - 110053.**

Sir,

This has a reference to your MHA Application no. 2024021801814 dated 18/02/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 26.02.2024 in the presence of Mr. Ram Chandra (Manager) and observed that building comprised of ground plus three upper floors only. **(Restaurant is running on ground floor only)**

Following shortcomings were observed during time of inspection:

1. Fire check door not provided.
2. There is two Entry/ Exit in the restaurant of width 1.50 meter & 0.80 meter against the requirement of two of width 1.50 meter each.
3. First-aid-Hose Reel not provided.
4. MOEFA not provided.
5. Fire pump of 450 LPM not provided.
6. Overhead tank capacity 20,000 liters not provided.
7. Exit signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-110024, w.r.t.- MHA Application no. 2024021801814 dated 18/02/2024.
2. The Manager, Shahi Darbar located at Property No. old no. 700, Vijay Park Village Maujpur, Delhi - 110053.