



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

8/51  
7/5  
गणराज्य  
दिल्ली

No. F6/DFS/MS/GH/SZ/2024 | 87

Dated: 07/03/2024

To

The Joint Commissioner of Police,  
Office of Joint Commissioner of Police: Licensing,  
1st Floor, P. S Defence Colony, New Delhi.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Hari's Court Guest House located at 71, Ring Road, Lajpat Nagar, New Delhi.**

Sir,

With reference to the MHA online application no. 2024021201538 dated 15.02.2024 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 26.02.2024 in the presence of Mr. Vinit Gupta (Director) and it was observed that the building is comprised of Basement + Ground + 03 upper floors & Temporary structure on terrace floor. During the inspection following shortcomings were observed:

1. Temporary structure on terrace must be removed.
2. Combustible paneling in staircase must be removed.
3. FCD's must be installed at every floor to segregate both the staircase.
4. Common corridor must have provision for smoke ventilation.
5. Fire pump & Hose reel shall be made functional.
6. CO detectors shall be provided in every room and common areas.
7. MOEFA shall be made functional.
8. Exit & lift signages must be provided in building.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
w. Gh  
28/2/24