



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

0135

7/5  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2024 | 107

Dated: 08/03/2024

To

The Principal,  
K.S.K. Academy Sr. Sec. Public School,  
H-117, Ratiya Marg, Sangam Vihar, New Delhi-80.

**Sub:-** Regarding issuance of Fire Safety Certificate in r/o **K.S.K. Academy Sr. Sec. Public School located at H-117, Ratiya Marg, Sangam Vihar, New Delhi-80.**

Sir,

With reference to your email dated on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 02.03.2024 in the presence of Mr. Narender Singh Chahal (Manager) and it was observed that the school building is comprised of ' Lower Ground + Ground + 03 upper floors. During the inspection following shortcomings were observed:-

1. 2 nos. of hose reels each at lower ground and ground floor found removed.
2. Fire pump found non functional.
3. Exit sinages found removed

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

**Copy to:-**

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

08/03/24