

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/ 95

Dated: 11 / 03 / 2024

To

The Dy. Health Officer, MCD,  
Public Health Department, Green Park Zone,  
Aurobindo Marg, New Delhi 110016.

Sub: Regarding issuance of Fire Safety Certificate in r/o **M/s LAIR** (A Unit of Naaya Hospitality LLP) located at 15, Basant Lok Vasant Vihar, New Delhi 110057

Sir,

This has reference with **MHA Portal ID 2024020601300 dated 06/02/2024** on the subject cited above. In this concerned, it is to inform you that the premise was inspected by the concern nominated authority of this department on 19/02/2024 in presence of Mr. Ravi Yadav to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid hose reel provide but found not working.
2. Automatic sprinkler system provided but found not working.
3. Internal hydrant system found removed.
4. Fire fighting pump are not on auto mode and also fire piping is found damaged need to be repaired.
5. Over head water tank connected with RO system is not allowed.
6. The Exit Signage found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

*g m*