



No. F6/DFS/MS/WZ/2024/ En 94

Dated:-

08/03/2029

To,

The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.

Sub.:- Regarding issuance of Fire Safety Certificate in respect of M/s. Pizza Hut (A Unit of Ms Devyani International Ltd.) located at Plot No. 1, Block-A, Subham Enclave, Paschim Vihar, Delhi-110063

This has reference to online application no. 2024021601745 dated 17/02/2024 on the subject Sir. cited above. In this connection, it is to inform you that the said building have been inspected by the officer concerned of this department on 05/03/2024 in the presence of Sh. Deepak (Jr. Manager) During inspection, it has been observed that the said restaurant is running at upper ground floor of a building comprised of Basement + Stilt + Upper Ground Floor + 03 Upper Floors served with 02 staircase. However, the following shortcomings have been observed as under:-

- Two Doors of 2.15 & 1.40 mts is provided against 02 Doors having width 1.5 m each.
- 2. Width of staircases is 1.45, 1.40 mts against required width of 1.5 mts each.
- 3. Fire check door is not provided.
- 4. First aid hose reel is provided but found non-functional.
- Fire terrace pump could not be checked as access to pump is not provided.
- Overhead water storage tank could not be checked as access to tank is not provided.
- 7. The fourth floor is made with temporary structure and the same may be demolished / removed.

In view of the above shortcoming, the application for issuance Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Copy to:-

1. Sh. Abhishek Mittal, M/s. Pizza Hut (A unit of Ms Devyani International Ltd.), Plot No. 1, Block-A, Subham Enclave, Paschim Vihar, Delhi-110063.