

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/Hospital/2024/SZ/ 07

Dated 08 /03 /2024

To

The General Manager,
M/s Sitaram Bhartia Institute of Science & Research
B-16, Qutab Institutional Area, New Delhi 1100016

Sub: -Regarding issuance of Fire Safety Certificate in r/o M/s Sitaram Bhartia Institute of Science & Research located at B-16, Qutab Institutional Area, New Delhi 1100016

Sir,

This has reference with letter received through outdoor diary no 13652 dated 28/02/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.03.2024 in the presence of Dr. Shubhra Verma to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 Smoke management system provided but found not working.
- 2 Temporary structure at terrace level needs to be removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours
faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE