



75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2024/SZ/ 108

Dated: 11/03/2024

To

Mr. P. Venkateswara Rao Penta,  
(Unit Head, Finance & Administration)  
M/s Asian Development Bank,  
4, San Martin Marg, Chanakyapuri,  
New Delhi-110021

Sub: **Regarding renewal of Fire Safety Certificate in r/o Asian Development Bank at 4, San Martin Marg, Chanakyapuri, New Delhi-110021**

Sir,

Please refer to your letter received through outdoor diary No. 12149 dated 23/01/2024, on the subject cited above. In this connection, it is to inform you that the said premises was re-visited by the officer concerned of this department on 16/02/2024 in your presence to verify the compliance of shortcoming issued by this department vide letter No. F6/DFS/MS/2023/SZ/1824 dated 28/08/2023.

During the course of inspection, the following shortcomings were observed.

1. System was not integrated i.e. FM's switch & ventilation are not connected.
2. Electrical shaft found not sealed at 3<sup>rd</sup> Floor.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The concerned authority/statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Chief Architect, Department of Architecture & Environs, New Delhi Municipal Council, Palika Kendra, New Delhi-110001