



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F. 6. / DFS / MS / BP / 2024/ / / 0

Dated: 12/03/2024

To,

The Medical Superintendent,
Shri Ram Hospital, B-14,
Shankar Garden, Vikas Puri,
New Delhi – 110085.

Sub:- Forwarding the proposed layout plan in respect of Shri Ram Hospital, situated at B-14, Shankar Garden, Vikas Puri, New Delhi – 85 for providing guidelines regarding Fire NOC.

Sir,

This has a reference to the as-built plan, forwarded by MS (NH), DGHS, GNCTD on the subject cited above. In this connection it is to inform you that the plan has been examined and observed following shortcomings:

1. Plans are not on scale.
2. Layout plan / section / elevation plans are not provided.

In absence of above information, plans cannot be scrutinized from fire safety point of view. Therefore, plans are returned to you in original with request to advice the owner/architect to rectify the above shortcomings and re-submit the proposal for further consideration in the matter.

Yours faithfully

Encl.: As stated above


12/3/24
(Dr. S.K. Tomar)

Dy. Chief Fire Officer
Ph. 011-23412025

Copy to:

The Medical Superintendent, Nursing Homes,
Directorate General of Health Services,
Govt. of NCT of Delhi (Nursing Home Cell),
3rd Floor, Delhi Government Dispensary Building,
S-1, School Block, Shakarpur, Delhi – 110092.