

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2024/SZ/ 93

Dated: 12/03/2024

To

The Joint Commissioner of Police (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s The Grand Shoba located at
Kh. No 1031/1 Street No 6, Mahipalpur, New Delhi 110037

Sir,

This has reference with **MHA Portal 2024021001479 dated 12/02/2024** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 06/03/2024 in the presence of Mr. Vikram and observed that building comprised of Basement, Ground + 03 upper floors and following shortcomings were observed during inspection :

1. Fire check doors not provided as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE