



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आज़ादी का
अमृत महोत्सव

934

No. F6/DFS/MS/School/SZ/2024 109

Dated: 11/03/2024

To

The Principal,
Hakikat Rai Sarvodaya Kanya Vidyalaya,
Shiv Park, Khanpur, New Delhi-62,
School ID no. 1923062.

Sub:- Regarding issuance of Fire Safety Certificate in r/o **Hakikat Rai Sarvodaya Kanya Vidyalaya, Shiv Park, Khanpur, New Delhi-62 (School ID no. 1923062).**

Sir,

With reference to your letter no. HRSKV/KPR/2023-24/806 dated 31.01.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 02.03.2024 in the presence of Mrs. Purnima Kaushal (HOS) and it was observed that the school building is comprised of three blocks: A blocks - Ground + 03 upper floors, B & C blocks - Ground + 1 upper floor each. During the inspection following shortcomings were observed:-

1. First aid hose reels found non function.
2. Fire pump found non functional.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

05/3/24 o/c