

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 11b

Dated: 11 / 03 / 2024

To

The Authored Signatory,
Holy Child Auxilium School
R.K Puram Sec-XII, New Delhi-110022.

Sub: -Regarding Issuance of Fire Safety Certificate in r/o M/s Holy Child Auxilium School
at R.K Puram Sec-XII, New Delhi-22

Sir,

This has reference to your letter, received through outdoor diary no 12953 dated 12/02/2024 on the subject above. In this connection, it is to inform you that the officers concerned of this department inspected on dated 29/02/2024 in the presence of Mr. Prakash Ram (Care taker) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation

1. First aid hose reel provided but found not functional.
2. Fire fighting pumps are not on auto mode.
3. Exit signage found removed at some places.
4. Electrical meter found installed in the under staircases, which is not acceptable.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi -54