



To,

The Manager,
M/s Topper's Classes Private Limited,
1/52, Lalita Park, Laxmi Nagar, Delhi-110092.

Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Topper's Classes Private Limited located at 1/52, Lalita Park, Laxmi Nagar, Delhi-110092.

Sir,

This has a reference to your Email dated 06.02.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 21/02/2024 in the presence of Mr. Praveen kumar (Manager) and observed that building comprised of Basement (Store) + Ground + 03 upper floors only. (Coaching classes running is First & Second upper floor only).

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel not functionable.
2. Fire pump not functionable.
3. Overhead tank of 10,000 liters capacity is provided against the requirement of 15,000 liters.
4. Exit Signage's not provided.
5. Standby Power Supply not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE


Copy to: -

1. The Manager M/s Topper's Classes Private Limited located at 1/52, Lalita Park, Laxmi Nagar, Delhi-110092.
2. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi.