

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2024/GH/97

Dated: 14-03-2024

To,

Mr. Sanjeev Sehrawat,  
House No.270, Tarun Enclave,  
Pitampura,  
Delhi-110034.

**Sub:** Issue of FSC in r/o M/s Hotel Rama (Guest House), House No.10, Pocket-27, Sector-24, Rohini, Delhi-85.

Sir,

This is in reference to your online application No. 2024021201559 dated 21.02.2024 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 06.03.2024, in presence of **Mr. Trikesh (GRF)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Hose reel provided but not functional.
2. Manually operated electric fire alarm system provided but not functional.
3. CO detector system provided but not functional.
4. Terrace Fire pump with capacity of 900 LPM provided but not functional.
5. Hose boxes & internal hydrants on down comer found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt)  
[p://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](p://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)  
DIRECTOR

Ph; 011-23414000

Copy to:-

1. MHA Portal ID. 2024021201559 dated 21.02.2024.