

530

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/98

Dated:- 14/03/2024

To,

The Manager,
M/S Hotel Worth, Guest House,
Plot no. 02; Block no. 80-A,
Krishna Market, Pahar Ganj,
New Delhi.

Sub: Regarding renewal of FSC in r/o M/S Hotel Worth, Guest House located at Plot no. 02, Block no. 80-A, Krishna Market, Pahar Ganj, New Delhi.

Sir,

This has reference to your online ID No. 2024022802314 dated 28/02/2024, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 06.03.2024 in presence of Manager and following shortcomings were observed:

1. Fire Check door are not installed as per gazette notification 27.05.2019.
2. Smoke management & CO detectors are not installed as per gazette notification 27.05.2019.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.