



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No: F.6/DFS/MS/WZ/Coaching Centre/2024/ 128
To

Dated: - 18/03/2024

The Authorized Signatory,
BYJUS'S Tuition Centre,
Property No. 2nd floor 1/81, Club Road,
West Punjabi Bagh, New Delhi - 110026.

Sub.-: Regarding issuance of Fire Safety Certificate in r/o BYJUS'S Tuition Centre, property No. 1/81, 2nd floor, Club Road, West Punjabi Bagh, New Delhi - 110026.

Sir,

Please refer to your letter no. Nil, received through Outdoor Diary No.- 5094 dated 18/08/2023, on the subject cited above. In this connection, it is to inform you that the building/premises have been inspected by the officer concerned of this department on 06/03/2024 in the presence of Sh. Nikhil Kr. Malhotra (Snior Business Head), to check the provisioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the building is comprised of Basemen + stilt + ground + three upper floors. Fire safety arrangements such as fire extinguishers, first -Aid hose reel, MOEFA, Internal hydrant, pumping arrangements, water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

1. First- Aid Hose reel & Internal Hydrant is not provided.
2. Main Fire Pump of capacity 450 lpm is not provided.
3. Over Head water storage tank capacity of 10,000 ltrs is not provided.
4. Exit Signages are not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

(Atul Garg)
Director

18/03/24
15/3/2024