



No. F6/DFS/MS/Cinema/NDZ/2024/126

Dated: 15/03/2024

To,

The Manager,
Chand Cinema,
Trilok Puri, Delhi - 110091.

Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Chand Cinema located at Trilok Puri, Delhi - 110091.

Sir,

This has a reference to your MCD Id no. 10060702 dated 08.03.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 14/03/2024 in the presence of Mr. Vikas Tyagi (Manager) and observed that building comprised of Three Basements, Ground plus four upper floors only.

Following shortcomings were observed during time of inspection:

1. Work for provision of fire check doors is in progress.
2. Pressurization fans provided but not functional.
3. First-Aid-Hose Reels not functional
4. Automatic Fire Detection and Alarming System provided but not functional
5. MOEFA provided but not functional
6. Public Address system provided but not functional
7. Internal Hydrants provided but not functional
8. Yard Hydrants provided but not functional
9. Fire pumps provided but not functional
10. Exit & floors Signage's not provided in strategic location in the building.
11. Work is in progress for installation fire system panel.
12. Overhead tank inspection ladder not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected.

Yours faithfully,

(ATUL GARG)
DIRECTOR

e/c DELHI FIRE SERVICE

Copy to: -

1. The Manager, Chand Cinema located at Trilok Puri, Delhi - 110091.
2. The Commissioner, Municipal Corporation of Delhi, 419 Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.