

c/38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/SZ/2024/ 124

Dated:- 15-03-2024

To,

The Manager,
Delight Public School,
Nawada Housing Complex, Near Dawarka Mor, New Delhi- 59.

Sub: - Regarding issuance of fire safety certificate in r/o Delight Public School at Nawada Housing Complex, Near Dawarka Mor, New Delhi- 59.

Sir,

Please refer to your letter No. Delight/Fire Noc/27/04/1/renewal, dated 26.02.2024, on the subject cited above. In this connection it is to inform you that the school building was inspected by the officer concerned of this department from safety point of view on 05.03.2024 in presence of Mr. Ankur Papreja (Manager), and found that the school building comprised of ground plus three upper floors, earlier FSC issued by this department vide letter No. F.6/DFS/MS/School/2020/SZ/68 dated 29.04.2020 for ground and first floor only but now the school running at ground plus two upper floor and two rooms at third floor found blocked.

During the course of inspection, the following shortcomings have been observed: -

- 1 Two staircases having width of 1.0 mtr each found provided against requirement of two staircases having width of 1.5 mtr each.
- 2 Terrace pump capacity of 220 LPM found provided against requirement capacity of 450 LPM.
- 3 Overhead water storage tank found 2,500 ltrs against requirement of 10,000 ltrs.
- 4 Exit Signage found not provided.

Keeping in view of above, fire safety certificate cannot be considered at this stage. School management requested to rectify the above said shortcomings for taking further necessary action in this matter.

Yours faithfully


(Ajay Garg)
Director

Delhi Fire Service

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.

For information please.