

c/63

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/104

dated: 15/03/2024

To

The Dy. Health Officer, MCD,
Public Health Department, Green Park Zone,
Aurobindo Marg, New Delhi 110016.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Pind Balluchi- Grills & Platters, A-3, Ground Floor, Pamposh Enclave, Greater Kailash-I, New Delhi -48


Sir,

This has reference with **MHA Portal ID 2024022602184 dated 26/02/2024** on the subject cited above. In this concerned, it is to inform you that the premise was inspected by the concern nominated authority of this department on 10/03/2024 in the presence of Mr. Rajiv Kumar (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire cheek door found removed at Stilt & ground floor.
2. First aid hose reel provided but found nonfunctional
3. MOEFA not working.
4. Fire fighting pumps provided but found not working.
5. Overhead tank capacity 10,000 ltr provided but found empty.
6. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARGI)
DIRECTOR
DELHI FIRE SERVICE

Copy To:-

1. The Addl. Commissioner of Police, Lic Branch, 1st Floor, PS Defence colony, New Delhi -49