



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2024/ 113

Dated: 13/03/2024

To

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Civic Centre, JLN Marg,
New Delhi- 110002.

Sub:- Rejection of building plans from fire safety point of view in r/o Industrial building at Plot No. 51, Block-A, Mangolpuri Industrial Area, Phase-I, New Delhi.

Sir,

With reference to request ID no. 10118218 dated 06.03.2024 on the subject cited above; it is informed that the referred online building plans in respect of proposed construction of Industrial Building at Plot No. 51, Block-A, Mangolpuri Industrial Area, Phase-I, New Delhi were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. Occupancy as per clause 1.4.75 of UBBL - 2016 and plans are not matching.
2. Fire prevention and fire safety measures are not prescribed as per occupancy.
3. There is difference in information provided in CAF and the plans submitted.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Garg)
Director
C.A.O.