

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/ BB/ 120

Dated: 15/03/2024

To,

The Authorized Signatory
Plot No. A-7, Commercial Complex,
Near Batra Cinema, Dr. Mukherjee Nagar, Delhi-09.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Plot No. A-7, Commercial Complex,
Near Batra Cinema, Dr. Mukherjee Nagar, Delhi-110009.

Sir,

Please refer to your letter received through online e-mail <naisadiprakashan@gmail.com> dated 06.03.2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 11.03.2024 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Satish Verma was also present at site. During the course of the inspection it is observed that the building is comprised of basement (sealed by MCD), ground, mezzanine & 03 upper floors only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Fire check doors found removed.
2. Terrace level fire water tank 20,000ltr provided against the requirement of 50,000ltr.
3. Exit & floors signage's found removed at strategic location in the building.
4. The basement was found sealed by MCD Department and inspection could not be carried out.
5. Standby power supply found removed in the building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph: 011-23414000

13/3