

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F.6/DFS/MS/2024/NDZ/ 134

Dated 26/03/2024

To,

Mr. Ashutosh Kumar,  
IMS Learning Resources Pvt. Ltd.,  
FF, A-19, Onkardeep Building,  
Middle Circle, Connaught Place,  
New Delhi.

**Sub:- Regarding issuance of FSC in r/o M/S FF, A-19, Onkardeep Building, Middle Circle, Connaught Place, New Delhi.**

Sir,

This has reference to your letter no. **nil** dated **12.02.2024**, on the subject cited above, it is to inform that the site was inspected by the officers concerned of this department on 12.03.24 in the presence of **care taker** and the following shortcomings were observed: -

1. 02 staircase of 1.5 meter are required against the provision of 01 staircase of 1.40 meter.
2. First Aid Hose reel found nonfunctional.
3. Over head tank found empty.
4. Electric shafts not sealed.
5. Fire extinguishers are due for refilling.
6. Smoke management system is not provided.
7. Sprinkler not provided in basement.
8. Exit signages and lift signages not provided.
9. Further, the building was approved under business occupancy from this department for the composition of basement, ground and three upper floors, whereas now the building is existing of basement, ground and four upper and being used for educational purpose. Accordingly, sanctioned plan of the building is required to process the case as there is an addition of floors in the building.

Therefore, you are requested to comply the same for further consideration the matter.

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

The Chief Architect, NDMC, Palika Kendra, New Delhi.