

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ 129

DATED: 19/03/2024

To,

The Executive Engineer (Building).  
Nigam Bhawan, Anand Parbat,  
D.B Gupta Road, Karol Bagh,  
New Delhi - 110005

**Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Coaching center Located at Plot No. 42, Sector-12B, Dwarka, New Delhi – 110075.**

Sir,

Please refer to letter No DFS Outdoor diary No. 12699, dated 05/02/2024 on the subject cited above. In this connection it is to inform you that the above said building has been inspected by the officers concerned of this department on 06/03/2024 in presence of Mr. Sahil Yadav (Representative) from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Two staircases of width 135 cm & 150 cm found provided against required 02 staircase of 1.5 m clear width.
2. The Passage to staircases found obstructed.
3. Two exit doors of 1m clear width not provided for each class room where students are more than 45.
4. Fire Check Door is not provided in basement floor.
5. Smoke exhaust system found not provided in basement
6. Terrace pump found provided but not on auto mode.
7. Overhead fire water tank of 5000 ltr capacity found provided against required capacity of 15000 ltr.
8. Exit Signage found not provided at some places.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation to this department for further consideration in the matter.

(Atul Garg)  
(Director)  
Delhi Fire Service

Copy to:-

1. The, Owner/ Occupier Coaching center Located at Plot No. 42, Sector-12B, Dwarka, New Delhi – 110075.