

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Metro/2024/SZ/ 139

Dated: 20/03/2024

To

The Chief General Manager/V& Y
Delhi Metro Rail Corporation,
Metro Bhawan, Fire Brigade Lane,
New Delhi 110001

Sub: - Regarding issuance of FSC in R/o DMRC Hauz Khas underground Metro Station (Line-8) New Delhi

Sir,

This has reference to your letter no DMRC/O&M/Fire/NOC/L-B/2024/02/04 Dated 06/02/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.03.2024 in the presence of Mr. Bhirgu Fukan (AM/Fire) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Some of the hose cabinet found damaged and need to be repaired / replaced.
2. Some of the electrical shaft not found properly sealed.
3. Fire rated inspection door not provided at electrical panel board at PD area.
4. LV Electrical panels are not provided with clear agent flooding system.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GANG)
DIRECTOR
DELHI FIRE SERVICE

9/4